

SOLUTIONS MANUAL

THERMAL ENVIRONMENTAL ENGINEERING T H I R D E D I T I O N

**Thomas H. Kuehn
James W. Ramsey
James L. Threlkeld**

PRENTICE HALL , Upper Saddle River, NJ 07458

Acquisitions Editor: Laura Curless
Supplement Editor: Lauri S. Friedman
Special Projects Manager: Barbara A. Murray
Production Editor: Maria T. Molinari
Supplement Cover Manager: Paul Gourhan
Supplement Cover Designer: PM Workshop Inc.
Manufacturing Buyer: Dawn Murrin

© 2000 by Prentice Hall
Upper Saddle River, NJ 07458

All rights reserved. No part of this book may be reproduced, in any form or by any means, without permission in writing from the publisher.

Printed in the United States of America

10 9 8 7 6 5 4 3 2 1

ISBN 0-13-917238-6

Prentice-Hall International (UK) Limited, London
Prentice-Hall of Australia Pty. Limited, Sydney
Prentice-Hall Canada, Inc., Toronto
Prentice-Hall Hispanoamericana, S.A., Mexico
Prentice-Hall of India Private Limited, New Delhi
Pearson Education Asia Pte. Ltd., Singapore
Prentice-Hall of Japan, Inc., Tokyo
Editora Prentice-Hall do Brazil, Ltda., Rio de Janeiro

2.1

$$a) 28.75 \text{ in Hg} \left(\frac{1.450 \times 10^{-4} \text{ psia}}{2.961 \times 10^{-4} \text{ in Hg}} \right) = 14.08 \text{ psia}$$

$$b) 28.75 \text{ in Hg} \left(\frac{4.019 \times 10^{-3} \text{ in H}_2\text{O}}{2.961 \times 10^{-4} \text{ in Hg}} \right) = 390.2 \text{ in H}_2\text{O}$$

$$c) \frac{390.23 \text{ in H}_2\text{O}}{0.8} \left(\frac{1 \text{ m}}{39.37 \text{ in}} \right) = 12.39 \text{ m fluid}$$

$$d) 28.75 \text{ in Hg} \left(\frac{1 \text{ Pa}}{2.961 \times 10^{-4} \text{ in Hg}} \right) = 97.10 \text{ kPa}$$

2.7

The energy balance on the evaporator is

$$\dot{Q}_{1-2} = \dot{m}_{\text{ref}} (h_2 - h_1)$$

at ①, by Table A.2 SI, $h_f = 88.73$, $h_g = 1417.81 \frac{\text{kJ}}{\text{kg}}$

$$h_1 = 88.73 + 0.3(1417.81 - 88.73) = 487.45 \frac{\text{kJ}}{\text{kg}}$$

at ②, by Table A.2 SI, $h_2 = h_g = 1417.81 \frac{\text{kJ}}{\text{kg}}$

Thus

$$\dot{Q}_{1-2} = \frac{1 \text{ kg}}{\text{s}} \left(1417.81 - 487.45 \right) \frac{\text{kJ}}{\text{kg}} = 930.4 \text{ kW}$$




Chart C-3E

Problem 8.29

ASHRAE PSYCHROMETRIC CHART NO. 1


NORMAL TEMPERATURE
BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992


AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING ENGINEERS, INC.

SEA LEVEL

$$SHR = 0.55$$



$$\frac{\text{ENTHALPY}}{\text{HUMIDITY RATIO}} = \frac{h}{W}$$



Prepared by: CENTER FOR APPLIED THERMODYNAMIC STUDIES, University of Idaho

14.20 The 97.5% design temp. for Chicago is
 -4°F (Table B.1)

a.) Walls

Source	Thermal Resistances, $\frac{\text{hr}\cdot\text{ft}^2\cdot^{\circ}\text{F}}{\text{Btu}}$	
	At studs	Between studs
Inside air film	0.68	0.68
3/8-inch gypsum	0.32	0.32
Studs	6.875	—
Insulation	—	19
25/32-inch sheathing	2.06	2.06
1.5-inch polystyrene*	7.5	7.5
4-inch brick **	0.6	0.6
Outside air film	0.17	0.17
Totals.	18.21	30.33

* Arbitrarily selected extruded polystyrene

** Arbitrarily selected lowest R-value/inch

Using the parallel path method, By Eqs 14.18 and 14.12

$$(U_{aw})_{\text{walls}} = \frac{0.25}{18.21} + \frac{0.75}{30.33} = 0.038 \text{ Btu/hr}\cdot\text{ft}^2\cdot^{\circ}\text{F}$$

Windows: $U_o = 0.33$ from Table 14.5

Roof: $U_R = 1/9.0 = 0.111 \text{ Btu/hr}\cdot\text{ft}^2\cdot^{\circ}\text{F}$

Doors: $U_D = 0.20$ from Table 14.7

$$A_{\text{windows}} = 700 \text{ ft}^2, A_{\text{doors}} = 40.5 \text{ ft}^2$$

$$A_{\text{walls, frame}} = (50 \times 10 \times 4) - 700 - 40.5 = 1259.5 \text{ ft}^2$$

$$A_{\text{Roof}} = 2500 \text{ ft}^2$$