

# **SOLUTIONS MANUAL**

## **THERMAL ENVIRONMENTAL ENGINEERING** T H I R D E D I T I O N

**Thomas H. Kuehn**  
**James W. Ramsey**  
**James L. Threlkeld**

PRENTICE HALL , Upper Saddle River, NJ 07458

Acquisitions Editor: Laura Curless  
Supplement Editor: Lauri S. Friedman  
Special Projects Manager: Barbara A. Murray  
Production Editor: Maria T. Molinari  
Supplement Cover Manager: Paul Gourhan  
Supplement Cover Designer: PM Workshop Inc.  
Manufacturing Buyer: Dawn Murrin

© 2000 by Prentice Hall  
Upper Saddle River, NJ 07458

All rights reserved. No part of this book may be reproduced, in any form or by any means, without permission in writing from the publisher.

Printed in the United States of America

10 9 8 7 6 5 4 3 2 1

ISBN 0-13-917238-6

Prentice-Hall International (UK) Limited, London  
Prentice-Hall of Australia Pty. Limited, Sydney  
Prentice-Hall Canada, Inc., Toronto  
Prentice-Hall Hispanoamericana, S.A., Mexico  
Prentice-Hall of India Private Limited, New Delhi  
Pearson Education Asia Pte. Ltd., Singapore  
Prentice-Hall of Japan, Inc., Tokyo  
Editora Prentice-Hall do Brazil, Ltda., Rio de Janeiro

2.1

$$a) 28.75 \text{ in Hg} \left( \frac{1.450 \times 10^{-4} \text{ psia}}{2.961 \times 10^{-4} \text{ in Hg}} \right) = 14.08 \text{ psia}$$

$$b) 28.75 \text{ in Hg} \left( \frac{4.019 \times 10^{-3} \text{ in H}_2\text{O}}{2.961 \times 10^{-4} \text{ in Hg}} \right) = 390.2 \text{ in H}_2\text{O}$$

$$c) \frac{390.23 \text{ in H}_2\text{O}}{0.8} \left( \frac{1 \text{ m}}{39.37 \text{ in}} \right) = 12.39 \text{ m fluid}$$

$$d) 28.75 \text{ in Hg} \left( \frac{1 \text{ Pa}}{2.961 \times 10^{-4} \text{ in Hg}} \right) = 97.10 \text{ kPa}$$




Chart C-3E

Problem 8.29



ASHRAE PSYCHROMETRIC CHART NO. 1


NORMAL TEMPERATURE  
BAROMETRIC PRESSURE: 29.921 INCHES OF MERCURY

COPYRIGHT 1992


AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING ENGINEERS, INC.

SEA LEVEL

$SHR = 0.55$



$\frac{\text{ENTHALPY}}{\text{HUMIDITY RATIO}} = \frac{h}{W}$



Prepared by: CENTER FOR APPLIED THERMODYNAMIC STUDIES, University of Idaho

ENTHALPY:  $h_{1A} \approx 24.5$   
 $h_{2B} \approx 27.2$   
HUMIDITY RATIO OF DRY AIR:  $W_{1A} \approx 0.01$   
 $W_{2B} \approx 0.015$

5/5

11.18

Summary of results

Component	Part(a)	Part(b)
$R_{i,w}$ hr ft <sup>2</sup> /lbm a	0.00923	0.00923
$R_{F,w}$ "	0.01157	0.01174
$R_{o,w}$ "	0.03417	0.03001
$R_{t,w}$ "	0.05497	0.05098
$R_{i,w} / R_{t,w}$	16.8%	18.1%
$R_{F,w} / R_{t,w}$	21.0%	23.0%
$R_{o,w} / R_{t,w}$	62.2%	58.9%
$U_{o,w}$ Btu/hr ft <sup>2</sup> (Btu/lbm a)	18.2	19.6

14.20 The 97.5% design temp. for Chicago is  
 $-4^{\circ}\text{F}$  (Table B.1)

a.) Walls

Source	Thermal Resistances, $\frac{\text{hr}\cdot\text{ft}^2\cdot^{\circ}\text{F}}{\text{Btu}}$	
	At studs	Between studs
Inside air film	0.68	0.68
3/8-inch gypsum	0.32	0.32
Studs	6.875	—
Insulation	—	19
25/32-inch sheathing	2.06	2.06
1.5-inch polystyrene*	7.5	7.5
4-inch brick **	0.6	0.6
Outside air film	0.17	0.17
Totals.	18.21	30.33

\* Arbitrarily selected extruded polystyrene

\*\* Arbitrarily selected lowest R-value/inch

Using the parallel path method, By Eqs 14.18 and 14.12

$$(U_{aw})_{\text{walls}} = \frac{0.25}{18.21} + \frac{0.75}{30.33} = 0.038 \text{ Btu/hr}\cdot\text{ft}^2\cdot^{\circ}\text{F}$$

Windows:  $U_o = 0.33$  from Table 14.5

Roof:  $U_R = 1/9.0 = 0.111 \text{ Btu/hr}\cdot\text{ft}^2\cdot^{\circ}\text{F}$

Doors:  $U_D = 0.20$  from Table 14.7

$$A_{\text{windows}} = 700 \text{ ft}^2, A_{\text{doors}} = 40.5 \text{ ft}^2$$

$$A_{\text{walls, frame}} = (50 \times 10 \times 4) - 700 - 40.5 = 1259.5 \text{ ft}^2$$

$$A_{\text{Roof}} = 2500 \text{ ft}^2$$

Problem 17.13 Bin Calculation, Denver Weather Data, Air to Air Heat Pump Heating											
(UA)effective = Btu/hr	1122	This is the effective (UA)-value for the building									
ti, °F=	68	Indoor temperature									
internal gain=	9000	This is the sum of internal gains expected									
Heat Pump Capacity=	$Q_{cond} = 17,200 + 385t_o + 2.54t_o^2$ Btu / hr										
Dc=	0.25	This is the part load degradation coefficient									
Power Requirement=	$W_{comp} = 1.28 + 0.0093t_o - 0.000085t_o^2$ kW										
tz, °F=	60.0	This is the calculated Zero-load temp.									
A	B	C	D	E	F	G	H	I			
Avg. Bin Temp °F	Annual Hours From Bin Data	Heating System Load, Btu/hr (can't be <0)	Heat Pump Capacity, Btu/hr	Part Load facto PLF PLF eqn (can't be > 1)	Run Time Hrs B°C/(D*E) (can't be > col. B)	Compressor Power kW	Backup Energy kWh (C-D)/B/3412 (can't be < 0)	Energy Input kWh (F*G)+H			
62	794	0	50834	0.750	0	1.53	0	0		0	
57	776	3342	47397	0.768	71	1.53	0	109		109	
52	739	8952	44088	0.801	187	1.53	0	287		287	
47	729	14562	40906	0.839	309	1.53	0	473		473	
42	752	20172	37851	0.883	454	1.52	0	690		690	
37	724	25782	34922	0.935	572	1.51	0	862		862	
32	704	31392	32121	0.994	692	1.49	0	1031		1031	
27	555	37002	29447	1.000	555	1.47	1229	2044		2044	
22	394	42612	26899	1.000	394	1.44	1814	2383		2383	
17	243	48222	24479	1.000	243	1.41	1691	2034		2034	
12	137	53832	22186	1.000	137	1.38	1271	1460		1460	
7	84	59442	20019	1.000	84	1.34	971	1083		1083	
2	54	65052	17980	1.000	54	1.30	745	815		815	
-3	22	70662	16068	1.000	22	1.25	352	380		380	
-8	13	76272	14283	1.000	13	1.20	236	252		252	
-13	5	81882	12624	1.000	5	1.14	101	107		107	
-18	3	87492	11093	1.000	3	1.09	67	70		70	
-23	1	93102	9689	1.000	1	1.02	24	25		25	
								Annual Energy Input in kWh=			14108